



◆◆ HOLD DOWN STRAP LOCATION * FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		Notes		DRAWING NUMBER:		REVISION:	
FLAT No.	SIZE	ITEM	DESCRIPTION	No	Revision Details	By	Date		
DOM 2	100NB	DUAL SOCKET	2 x 100NB BSP SOCKET						
3	100NB	DUAL SOCKET	2 x 100NB BSP SOCKET						
2	100NB	MONITOR	INTERSTICE MONITOR SOCKET						
1	100NB	DUAL SOCKET	2 x 100NB BSP SOCKET	A	Original Issue				

DATE: 23/07/01

DRAWN: V.B.B. **App. Weight:** 1,000 kg **Construction Type:** DOUBLE WALL TYPE 10

App. Capacity: 11,909 L **Notes:** - Tie-Down Straps to suit this tank are part no. - Dedmen to suit this tank are part no. - UNO, all sockets are BSP and are c/w striker plates under.

COMPARTMENT CONFIGURATION: SINGLE

DRAWING NUMBER: F1 010000-002

REVISION: A

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
PO BOX 102
CARRINGTON., NSW 2294
Ph:(02)4961-2745 Fax:(02)4962-2812

FIBRETANK SYSTEMS Pty Limited