



◆◆ HOLD DOWN STRAP LOCATION * FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FIBRETANK SYSTEMS Pty Limited

FITTING SCHEDULE		DESCRIPTION		Notes		DRAWING NUMBER:		REVISION:	
FLAT No.	SIZE	ITEM	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	No	Revision Details	By	Date		
DOM 2	100NB	SOCKET	100NB BSP SOCKET						
3	100NB	MONITOR	INTERSTICE MONITOR SOCKET						
1-2	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	A	Original Issue				

DRAWN: V.B.B. App. Weight: 770 KG
 DATE: 23/07/01 App. Capacity: 11,864 L

Construction Type: DOUBLE WALL TYPE 10
 Compartment Configuration: SINGLE

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
 PO BOX 102
 CARRINGTON., NSW 2294
 Ph:(02)4961-2745 Fax:(02)4962-2812