



TANK 1 VOLUME = 62,186 L

TANK 2 VOLUME = 49,095 L

▶▶ HOLD DOWN STRAP LOCATION

* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		Notes		Revision Details	
FLAT No.	SIZE	ITEM		No	By	Date	
29	100NB	SOCKET	100NB BSP SOCKET				
28	100NB	SOCKET	100NB BSP SOCKET				
27	100NB	SOCKET	100NB BSP SOCKET				
24	100NB	SOCKET	100NB BSP SOCKET				
22-23	100NB	MONITOR	INTERSTICE MONITOR SOCKET				
13-20	100NB	SOCKET	100NB BSP SOCKET				
6	100NB	SOCKET	100NB BSP SOCKET				
4-5	100NB	MONITOR	INTERSTICE MONITOR SOCKET				
2-3	100NB	SOCKET	100NB BSP SOCKET				
1	100NB	SOCKET	100NB BSP SOCKET				

FIBRETANK SYSTEMS Pty Limited

DRAWN: V.B.B. App. Weight: 4,379 kg

Construction Type DOUBLE WALL TYPE 110

Compartment Configuration DOUBLE 60/50

REVISION: A

DATE: 25-07-01 App. Capacity: 111,281 L

Description

DRAWING NUMBER: FK 110000-000

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
PO BOX 102
CARRINGTON, NSW 2294
Ph:(02)4961-2745 Fax:(02)4962-2812