



TANK 1 VOLUME = 81,824 L

TANK 2 VOLUME = 29,457 L

▶ ◀ HOLD DOWN STRAP LOCATION * FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE	FLAT No.	SIZE	ITEM	DESCRIPTION	Notes	No	Revision Details	By	Date
	DOME	100NB	MONITOR	INTERSTICE MONITOR SOCKET					
	27-28	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID					
	25	100NB	SOCKET	100NB BSP SOCKET					
	24	100NB	SOCKET	100NB BSP SOCKET (VENT ONLY)					
	20	100NB	SOCKET	100NB BSP SOCKET					
	10	100NB	SOCKET	100NB BSP SOCKET	- Tie-Down Straps to suit this tank are part no.				
	4-5	100NB	MONITOR	INTERSTICE MONITOR SOCKET	- Deadmen to suit this tank are part no.				
	2-3	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	- UNO, all sockets are BSP and are c/w striker plates under.	A	Original Issue	-	-

DRAWN: V.B.B.	App. Weight: 4,467 kg	Construction Type	DOUBLE WALL TYPE 110	Compartment Configuration	DOUBLE 80/30	DRAWING NUMBER:	FE 110000-001	REVISION:	A
DATE: 1-07-02	App. Capacity: 111,281 L								

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
PO BOX 102
CARRINGTON., NSW 2294
Ph:(02)4961-2745 Fax:(02)4962-2812