



FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

▶▶ HOLD DOWN STRAP LOCATION

FITTING SCHEDULE		DESCRIPTION		Notes		DRAWING NUMBER:		REVISION:	
FLAT No.	SIZE	ITEM	DESCRIPTION	Notes		No	Revision Details	By	Date
29	100NB	SOCKET	100NB BSP SOCKET	- Tie-Down Straps to suit this tank are part no.		B	Socket added to Flat 25	KJM	17.07.07
27-28	100NB	MONITOR	INTERSTICE MONITOR SOCKET	- Dedmen to suit this tank are part no.		A	Original Issue	-	-
25	100NB	SOCKET	100NB BSP SOCKET	- UNQ, all sockets are BSP and are c/w striker plates under.					
16	100NB	SOCKET	100NB BSP SOCKET						
15	-	SUPA-RIB	INTERNAL SUPA-RIB						
6-7	100NB	MONITOR	INTERSTICE MONITOR SOCKET						
2-3	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID						
DRAWN: V.B.B.		App. Weight:	4,905 kg	Construction		Type		Compartment Configuration	
DATE: 24-07-01		App. Capacity:	111,281 L	DOUBLE WALL		TYPE 110		SINGLE	
The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.		All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.		THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED		FIBRETANK SYSTEMS Pty Limited PO BOX 102 CARRINGTON., NSW 2294 Ph:(02)4961-2745 Fax:(02)4962-2812			