



VOLUME TANK 1 = 39,206 Ltrs APPROX      VOLUME TANK 2 = 40,083 Ltrs APPROX      VOLUME TANK 3 = 29,405 Ltrs APPROX

NOTE: INTERNAL BULKHEADS ARE DOUBLE WALL

▶▶ HOLD DOWN STRAP LOCATION      \* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION	Notes	Revision Details	By	Date										
27-28	25						23-24	20	18	13-14	6	5	2-3	FLAT No.		
600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID														
100NB	DUPEX	2 x 100NB BSP SOCKETS														
100NB	MONITOR	INTERSTICE MONITOR SOCKET														
100NB	SOCKET	100NB BSP SOCKET														
100NB	SOCKET	100NB BSP SOCKET														
600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID														
100NB	SOCKET	100NB BSP SOCKET	- Tie-Down Straps to suit this tank are part no.													
100NB	SOCKET	100NB BSP SOCKET	- Dedmen to suit this tank are part no.													
600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID														
100NB	SOCKET	100NB BSP SOCKET														
600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID														
FLAT No.	SIZE	ITEM														

DRAWN: TAH	App. Weight: 7500 kg	Construction Type	DOUBLE WALL TYPE 110	Compartment Configuration	TRIPLE 40/40/30	DRAWING NUMBER:	FR 110000-011	REVISION:	A
DATE: 09-09-08	App. Capacity: 108,694 L	DESCRIPTION		Notes					

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The Tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited  
 PO BOX 102  
 CARRINGTON, NSW 2294  
 Ph:(02)4961-2745 Fax:(02)4962-2812