



FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		FIBRETANK SYSTEMS Pty Limited		
DOME	100NB	MONITOR	INTERSTICE MONITOR SOCKET	
6-7	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	- Tie-Down Straps to suit this tank are part no.
1-2	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	- Dedmen to suit this tank are part no.
FLAT No.	SIZE	ITEM	DESCRIPTION	Notes
				A Original Issue

DRAWN: V.B.B. App. Weight: 1,289 kg

DATE: 31-07-01 App. Capacity: 20,804 L

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

Construction Type DOUBLE WALL TYPE 20

Compartment Configuration DOUBLE 10/10

DRAWING NUMBER: FE 020000-000

Revision: A

FIBRETANK SYSTEMS Pty Limited
 PO BOX 102
 CARRINGTON, NSW 2294
 Ph:(02)4961-2745 Fax:(02)4962-2812