



TANK 1 VOLUME  
15,440 L APPROX

TANK 2 VOLUME  
10,728 L APPROX

FITTING SCHEDULE		FIBRETANK SYSTEMS Pty Limited	
DOME	100NB	SOCKET	100NB BSP SOCKET
11	100NB	SOCKET	100NB BSP SOCKET
10	100NB	DUPLEX	2 x 100NB BSP SOCKET
9	100NB	SOCKET	100NB BSP SOCKET
8-RIB	100NB	MONITOR	INTERSTICE MONITOR SOCKET
4	100NB	SOCKET	100NB BSP SOCKET
2	100NB	DUPLEX	2 x 100NB BSP SOCKET
1	100NB	SOCKET	100NB BSP SOCKET
DOME	100NB	SOCKET	100NB BSP SOCKET
FLAT No.	SIZE	ITEM	DESCRIPTION
DRAWN: V.B.B.		App. Weight:	1,452 kg
DATE: 24-07-01		App. Capacity:	26,168 L
Construction		Type	DOUBLE WALL TYPE 25
Notes		Compartment Configuration	DOUBLE
Revision Details		DRAWING NUMBER:	FK 025000-000
By	Date	REVISION:	A

\* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

▶▶ HOLD DOWN STRAP LOCATION

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited  
PO BOX 102  
CARRINGTON, NSW 2294  
Ph:(02)4961-2745 Fax:(02)4962-2812