



TANK 1 VOLUME
15,440 L APPROX

TANK 2 VOLUME
10,728 L APPROX

▶▶ HOLD DOWN STRAP LOCATION

* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		NOTES		REVISION:	
DOME	100NB	MONITOR	INTERSTICE MONITOR SOCKET			Revision Details	Date
9-10	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	- Tie-Down Straps to suit this tank are part no.			
2-3	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	- Dedmen to suit this tank are part no.			
DOME	100NB	SOCKET	100NB BSP SOCKET	- UNO, all sockets are BSP and are c/w striker plates under.			
FLAT No.	SIZE	ITEM	DESCRIPTION		No	Original Issue	-
DRAWN: V.B.B.		App. Weight:	1,534 kg	Construction		DOUBLE WALL TYPE 25	
DATE: 31-07-01		App. Capacity:	26,168 L	Type		DOUBLE	
				Compartment Configuration		DOUBLE 15/10	
				Drawing Number:		FE 025000-000	
				Revision:		A	

FIBRETANK SYSTEMS Pty Limited

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
PO BOX 102
CARRINGTON., NSW 2294
Ph:(02)4961-2745 Fax:(02)4962-2812