



FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		NOTES		REVISIONS	
FLAT No.	SIZE	ITEM	DESCRIPTION	No	Revision Details	By	Date
11	100NB	SOCKET	100NB BSP SOCKET				
9-10	100NB	MONITOR	INTERSTICE MONITOR SOCKET				
8	100NB	SOCKET	100NB BSP SOCKET				
2-3	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID				

DRAWN: V.B.B.		App. Weight: 1,410 kg		Construction Type		Compartment Configuration		DRAWING NUMBER:		REVISION:	
DATE: 23/07/01		App. Capacity: 26,168 L		DOUBLE WALL TYPE25		SINGLE		FD 025000-000		A	

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
 PO BOX 102
 CARRINGTON., NSW 2294
 Ph:(02)4961-2745 Fax:(02)4962-2812