



FITTING SCHEDULE		DESCRIPTION		NOTES		REVISION:			
FLAT No.	SIZE	ITEM	DESCRIPTION	No	Revision Details	By	Date		
DOME	100NB	SOCKET	100NB BSP SOCKET						
11-12	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID						
7	100NB	SOCKET	100NB BSP SOCKET						
6	100NB	SOCKET	100NB BSP SOCKET		- Tie-Down Straps to suit this tank are part no.				
2-3	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID		- Dedmen to suit this tank are part no.				
DOME	100NB	MONITOR	INTERSTICE MONITOR SOCKET		- UNO, all sockets are BSP and are c/w striker plates under.	A	Original Issue		
FLAT No.									
DRAWN:	V.B.B.	App. Weight:	1,700 kg	Construction	Type	Compartment Configuration	DRAWING NUMBER:		
DATE:	31-07-01	App. Capacity:	29,744	DOUBLE WALL TYPE 30		DOUBLE	FE 030000-000		
<p>The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage Tanks as illustrated. Sizes & fittings shall be as noted. The Tanks shall be "Century-Cast" Tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.</p>				<p>All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.</p>				<p>THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED</p>	
				<p>FIBRETANK SYSTEMS Pty Limited PO BOX 102 CARRINGTON., NSW 2294 Ph:(02)4961-2745 Fax:(02)4962-2812</p>					