



FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		Notes		DRAWING NUMBER:		REVISION:	
FLAT No.	SIZE	ITEM				No	Revision Details	By	Date
13	100NB	SOCKET	100NB BSP SOCKET						
11-12	100NB	MONITOR	INTERSTICE MONITOR SOCKET						
8	100NB	SOCKET	100NB BSP SOCKET						
3	100NB	SOCKET	100NB BSP SOCKET		- Tie-Down Straps to suit this tank are part no.				
2	100NB	SOCKET	100NB BSP SOCKET		- Dedmen to suit this tank are part no.				
1	100NB	SOCKET	100NB BSP SOCKET		- UNO, all sockets are BSP and are c/w striker plates under.	A	Original Issue		
DRAWN: V.B.B.		App. Weight: 2,535 kg		Construction Type		Compartment Configuration		DRAWING NUMBER: F1 030000-000	
DATE: 01-08-01		App. Capacity: 35,108 L		DOUBLE WALL TYPE30		SINGLE		A	

FIBRETANK SYSTEMS Pty Limited

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage Tanks as illustrated. Sizes & fittings shall be as noted. The Tanks shall be "Century-Cast" Tanks as manufactured by Fibretank Systems Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
PO BOX 102
CARRINGTON., NSW 2294
Ph:(02)4961-2745 Fax:(02)4962-2812