



FITTING SCHEDULE		DESCRIPTION		Notes		Revision Details	
FLAT No.	SIZE	ITEM		No	Original Issue	By	Date
1	100NB	SOCKET	100NB BSP SOCKET	A			
2	100NB	SOCKET	100NB BSP SOCKET				
3	100NB	SOCKET	100NB BSP SOCKET				
4-5	100NB	MONITOR	INTERSTICE MONITOR SOCKET				
7	100NB	SOCKET	100NB BSP SOCKET				
9	100NB	SOCKET	100NB BSP SOCKET				
14	100NB	DUPLEX	2 x 100NB BSP SOCKET				
15	100NB	SOCKET	100NB BSP SOCKET				
16	100NB	SOCKET	100NB BSP SOCKET				
DOME	100NB	SOCKET	100NB BSP SOCKET				

DATE: 24-07-01	App. Capacity: 35,108 L	Construction Type: DOUBLE WALL TYPE 35	Compartment Configuration: DOUBLE 25/10	DRAWING NUMBER: FK 035000-000	REVISION: A
DRAWN: V.B.B. App. Weight: 1,857 kg		DOUBLE WALL TYPE 35		FK 035000-000	
DATE: 24-07-01		DOUBLE WALL TYPE 35		FK 035000-000	

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.		All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.		THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED		FIBRETANK SYSTEMS Pty Limited PO BOX 102 CARRINGTON, NSW 2294 Ph:(02)4961-2745 Fax:(02)4962-2812	
--	--	--	--	--	--	---	--