



FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

▶▶ HOLD DOWN STRAP LOCATION

FITTING SCHEDULE		FIBRETANK SYSTEMS Pty Limited	
16	SOCKET	100NB BSP SOCKET	
14-15	MONITOR	INTERSTICE MONITOR SOCKET	
9	SOCKET	100NB BSP SOCKET	
2-3	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	
FLAT No.	SIZE	ITEM	DESCRIPTION
			Notes
			- Tie-Down Straps to suit this tank are part no.
			- Deadmen to suit this tank are part no.
			- UNO, all sockets are BSP and are c/w striker plates under.
			A Original Issue
			Revision Details
			By
			Date
DRAWN: V.B.B.		App. Weight:	1,762 kg
DATE: 23-07-01		App. Capacity:	35,108 L
		Construction	DOUBLE WALL
		Type	TYPE 35
		Compartment Configuration	SINGLE
		DRAWING NUMBER:	FD 035000-000
		REVISION:	A

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited  
 PO BOX 102  
 CARRINGTON., NSW 2294  
 Ph:(02)4961-2745 Fax:(02)4962-2812