



TANK 1 VOLUME = 20,804 L

TANK 2 VOLUME = 19,668 L

FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

▶▶ HOLD DOWN STRAP LOCATION

FITTING SCHEDULE		DESCRIPTION		Notes		Revision Details	
17-18	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID				
15	100NB	SOCKET	100NB BSP SOCKET				
12	100NB	SOCKET	100NB BSP SOCKET				
10-11	100NB	MONITOR	INTERSTICE MONITOR SOCKET				
8	100NB	SOCKET	100NB BSP SOCKET	- Tie-Down Straps to suit this tank are part no.			
5	100NB	SOCKET	100NB BSP SOCKET	- Dedmen to suit this tank are part no.			
2-3	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	- UNO, all sockets are BSP and are c/w striker plates under.			
FLAT No.	SIZE	ITEM	DESCRIPTION				

FIBRETANK SYSTEMS Pty Limited

DRAWN: V.B.B. App. Weight: 2,186 kg

Construction

Type

Compartment Configuration

DRAWING NUMBER:

REVISION:

DATE: 31-07-01 App. Capacity: 40,472 L

DOUBLE WALL

TYPE 40

DOUBLE

FE 04 0000 - 000

A

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited  
PO BOX 102  
CARRINGTON., NSW 2294  
Ph:(02)4961-2745 Fax:(02)4962-2812