



FIBRETANK SYSTEMS Pty Limited
 * FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		FIBRETANK SYSTEMS Pty Limited	
FLAT No.	SIZE	DESCRIPTION	Notes
19	100NB	SOCKET	
17-18	100NB	MONITOR	
16	100NB	SOCKET	
15	100NB	SOCKET	
11	100NB	SOCKET	
5	100NB	SOCKET	
4	100NB	SOCKET	
2-3	100NB	MONITOR	
1	100NB	SOCKET	
1	100NB	SOCKET	

DATE:	App. Capacity:	App. Weight:	Construction	Type	Compartment Configuration	DRAWING NUMBER:	REVISION:
30-10-03	40,472 L	1,990 kg	DOUBLE WALL	TYPE 40	SINGLE	F1 04 0000-000	A

DESCRIPTION	Notes	Revision Details	By	Date
Construction	- Tie-Down Straps to suit this tank are part no. - Dedmen to suit this tank are part no. - UNO, all sockets are BSP and are c/w striker plates under.	A Original Issue		

DATE:	App. Capacity:	App. Weight:	Construction	Type	Compartment Configuration	DRAWING NUMBER:	REVISION:
30-10-03	40,472 L	1,990 kg	DOUBLE WALL	TYPE 40	SINGLE	F1 04 0000-000	A

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
 PO BOX 102
 CARRINGTON., NSW 2294
 Ph:(02)4961-2745 Fax:(02)4962-2812