



▶▶ HOLD DOWN STRAP LOCATION \* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		Notes		Revision Details	
FLAT No.	SIZE	ITEM	DESCRIPTION	No	Original Issue	By	Date
19	100NB	SOCKET	100NB BSP SOCKET				
17-18	100NB	MONITOR	INTERSTICE MONITOR SOCKET				
11	100NB	SOCKET	100NB BSP SOCKET				
2-3	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	A	Original Issue		

DRAWN: V.B.B.	App. Weight: 1,990 kg	Construction Type	DOUBLE WALL TYPE 40	Compartment Configuration	SINGLE	DRAWING NUMBER:	FD 04 0000-000	REVISION:	A
DATE: 24-07-01	App. Capacity: 40,472 L	Description		Notes		Revision Details		Date	

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited  
 PO BOX 102  
 CARRINGTON., NSW 2294  
 Ph:(02)4961-2745 Fax:(02)4962-2812