



TANK 1 - 10,768 LITRES

TANK 2 - 19,062 LITRES

TANK 3 - 10,768 LITRES

▶▶ HOLD DOWN STRAP LOCATION

* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		FIBRETANK SYSTEMS Pty Limited	
19	100NB DUAL SOCKET	2 x 100NB DUAL SOCKET	
17-18	600NB MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	
14-15	100NB MONITOR	INTERSTICE MONITOR SOCKET	
12	100NB SOCKET	100NB BSP SOCKET	
11	100NB SOCKET	100NB BSP SOCKET	
8-9	600NB MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	- Tie-Down Straps to suit this tank are part no.
2-3	600NB MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	- Dedmen to suit this tank are part no.
1	100NB DUAL SOCKET	2 x 100NB DUAL SOCKET	- UNO, all sockets are BSP and are c/w striker plates under.
FLAT No.	SIZE	ITEM	DESCRIPTION
DRAWN: M.P.		App. Weight:	3,700 kg
DATE: 22-11-07		App. Capacity:	40,472 L
		Construction	Type
		DOUBLE WALL	TYPE 40
		Compartment Configuration	TRIPLE
		DRAWING NUMBER:	FR 04 0000-000
		Revision Details	No
		By	Date
		REVISION:	A

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
 PO BOX 102
 CARRINGTON, NSW 2294
 Ph:(02)4961-2745 Fax:(02)4962-2812