



TANK 1 VOLUME = 26,168 L

TANK 2 VOLUME = 19,668 L

▶▶ HOLD DOWN STRAP LOCATION

* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		Notes		Revision Details	
21	100NB	SOCKET	100NB BSP SOCKET			No	By
20	100NB	SOCKET	100NB BSP SOCKET				
19	100NB	SOCKET	100NB BSP SOCKET				
17	100NB	SOCKET	100NB BSP SOCKET				
15	100NB	SOCKET	100NB BSP SOCKET				
11	100NB	SOCKET	100NB BSP SOCKET				
7	100NB	SOCKET	100NB BSP SOCKET				
4-5	100NB	MONITOR	INTERSTICE MONITOR SOCKET	- Tie-Down Straps to suit this tank are part no.			
2-3	100NB	SOCKET	100NB BSP SOCKET	- Dedmen to suit this tank are part no.			
1	100NB	SOCKET	100NB BSP SOCKET	- UNQ, all sockets are BSP and are c/w striker plates under.			
FLAT No.	SIZE	ITEM					

DRAWN: V.B.B.	App. Weight: 2,262 kg	Construction Type	DOUBLE WALL TYPE 45	Compartment Configuration	DOUBLE 25/20	DRAWING NUMBER:	FK 045000-000	REVISION:	A
DATE: 24-07-01	App. Capacity: 51,200 L								

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
 PO BOX 102
 CARRINGTON., NSW 2294
 Ph:(02)4961-2745 Fax:(02)4962-2812