



TANK 1 VOLUME = 26,168 L

TANK 2 VOLUME = 19,668 L

▶▶ HOLD DOWN STRAP LOCATION

* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		Notes		Revision Details	
FLAT No.	SIZE	ITEM	DESCRIPTION	No	Original Issue	By	Date
19-20	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID				
17	100NB	SOCKET	100NB BSP SOCKET				
15	100NB	SOCKET	100NB BSP SOCKET				
11	100NB	SOCKET	100NB BSP SOCKET				
7	100NB	SOCKET	100NB BSP SOCKET				
5-6	100NB	MONITOR	INTERSTICE MONITOR SOCKET				
2-3	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID				
DRAWN: V.B.B.		App. Weight:	2,350 kg	Construction		Type	DOUBLE WALL
DATE: 31-07-01		App. Capacity:	44,048 L	Notes		Compartment Configuration	DOUBLE 25/20
				Description		DRAWING NUMBER:	FE 045000-000
				Notes		Revision Details	
				Notes		By	
				Notes		Date	
				Notes		REVISION:	A

FIBRETANK SYSTEMS Pty Limited

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
 PO BOX 102
 CARRINGTON., NSW 2294
 Ph:(02)4961-2745 Fax:(02)4962-2812