



* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

▶▶ HOLD DOWN STRAP LOCATION

FITTING SCHEDULE		DESCRIPTION		Notes		Revision Details	
FLAT No.	SIZE	ITEM		No	Original Issue	By	Date
21	100NB	SOCKET	100NB BSP SOCKET				
19-20	100NB	MONITOR	INTERSTICE MONITOR SOCKET				
18	100NB	SOCKET	100NB BSP SOCKET				
17	100NB	SOCKET	100NB BSP SOCKET				
12	100NB	SOCKET	100NB BSP SOCKET				
5	100NB	SOCKET	100NB BSP SOCKET				
4	100NB	SOCKET	100NB BSP SOCKET				
2-3	100NB	MONITOR	INTERSTICE MONITOR SOCKET				
1	100NB	SOCKET	100NB BSP SOCKET	A	Original Issue		

DRAWN: V.B.B.		App. Weight: 2,121 kg		Construction Type		DOUBLE WALL TYPE 45		Compartment Configuration		DRAWING NUMBER:		F1 045000-000		REVISION:		A	
DATE: 30-10-03		App. Capacity: 44,048 L		Description		DOUBLE WALL TYPE 45		SINGLE		F1 045000-000							

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
 PO BOX 102
 CARRINGTON, NSW 2294
 Ph:(02)4961-2745 Fax:(02)4962-2812