



FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

▶▶ HOLD DOWN STRAP LOCATION

FITTING SCHEDULE		DESCRIPTION		Notes		Revision Details	
SIZE	ITEM	DESCRIPTION	Notes	No	Original Issue	By	Date
22	100NB SOCKET	100NB BSP SOCKET	- Tie-Down Straps to suit this tank are part no.				
20-21	100NB MONITOR	INTERSTICE MONITOR SOCKET	- Dedmen to suit this tank are part no.				
12	100NB SOCKET	100NB BSP SOCKET	- UNO, all sockets are BSP and are c/w striker plates under.	A			
2-3	600NB MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID					
FLAT No.	SIZE	ITEM	DESCRIPTION	No	Revision Details	By	Date

FIBRETANK SYSTEMS Pty Limited

DRAWN: V.B.B. App. Weight: 2,121 kg

App. Capacity: 44,048 L

DATE: 23-07-01

Construction

Type

DOUBLE WALL TYPE 45 SINGLE

DRAWING NUMBER: FD 045000-000

REVISION: A

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
PO BOX 102
CARRINGTON., NSW 2294
Ph:(02)4961-2745 Fax:(02)4962-2812