

▶◀ HOLD DOWN STRAP LOCATION

✱ FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE

FLAT No.	SIZE	ITEM	DESCRIPTION
4	100NB	SOCKET	2 x 100NB BSP SOCKETS
2	100NB	SOCKET	100NB BSP SOCKET
2	100NB	DUPLEX	DUPLEX c/w 2 x 100NB BSP SOCKETS
DOME 1	100NB	MONITOR	INTERSTICE MONITOR SOCKET

Notes

- Tie-Down Straps to suit this tank are part no.
- Deadmen to suit this tank are part no.
- UNO, all sockets are BSP and are c/w striker plates under.

No	Revision Details	By	Date
A	Original Issue	–	–

FIBRETANK SYSTEMS Pty Limited

DRAWN: V.B.B.

DATE: 01-08-01

App. Weight: 380 kg

App. Capacity: 5,300 L

Construction	Type	Compartment Configuration
DOUBLE WALL	TYPE 5	SINGLE

DRAWING NUMBER: FI 005000-000

REVISION: A

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
PO BOX 102
CARRINGTON., NSW 2294
Ph:(02)4961-2745 Fax:(02)4962-2812