



TANK 1 VOLUME = 36,942 L

TANK 2 VOLUME = 14,304 L

▶◀ HOLD DOWN STRAP LOCATION

* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE	FLAT No.	SIZE	ITEM	DESCRIPTION	Notes	No	Revision Details	By	Date	
	DOME	100NB	SOCKET	100NB BSP SOCKET						
	25	100NB	SOCKET	100NB BSP SOCKET						
	23-24	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS						
	19-20	100NB	MONITOR	INTERSTICE MONITOR SOCKET						
	17	100NB	SOCKET	100NB BSP SOCKET						
	8	100NB	SOCKET	100NB BSP SOCKET	- Tie-Down Straps to suit this tank are part no.					
	6-7	100NB	MONITOR	INTERSTICE MONITOR SOCKET	- Deadmen to suit this tank are part no.					
	2-3	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS	- UNO, all sockets are BSP and are c/w striker plates under.	A	Original Issue	-	-	
DRAWN: V.B.B.		App. Weight: 2,674 KG		Construction	Type	Compartment Configuration		DRAWING NUMBER:		
DATE: 08-06-01		App. Capacity: 51,200 L		DOUBLE WALL	TYPE 50	DOUBLE 35-15		FE 050000-000		
The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.				All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.		THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED			FIBRETANK SYSTEMS Pty Limited PO BOX 102 CARRINGTON., NSW 2294 Ph:(02)4961-2745 Fax:(02)4962-2812	
								REVISION: A		