



FITTING SCHEDULE	
24-25	100NB MONITOR INTERSTICE MONITOR SOCKET
23	100NB SOCKET 100NB BSP SOCKET
22	100NB SOCKET 100NB BSP SOCKET
14	100NB SOCKET 100NB BSP SOCKET
6-7	100NB MONITOR INTERSTICE MONITOR SOCKET
3	100NB SOCKET 100NB BSP SOCKET
2	100NB SOCKET 100NB BSP SOCKET
1	100NB SOCKET 100NB BSP SOCKET
FLAT No.	ITEM

DRAWING: V.B.B.		App. Weight: 2,450 kg	
DATE: 6-5-02		App. Capacity: 51,200 L	
DESCRIPTION		DOUBLE WALL TYPE 50 SINGLE	
Construction		Type	
DOUBLE WALL		TYPE 50	
Type		SINGLE	
Notes		Revision Details	
- Tie-Down Straps to suit this tank are STP part no.		No	
- Deadmen to suit this tank are STP part no.		A	
- UNQ, all sockets are BSP and are c/w sticker plates under.		Original Issue	
Notes		Revision Details	
No		By	
Revision Details		Date	

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF STP GROUP PTY LTD

FIBRETANK SYSTEMS Pty Limited
 PO BOX 102
 CARRINGTON, NSW 2294
 Ph:(02)4961-2745 Fax:(02)4962-2812

▶▶ HOLD DOWN STRAP LOCATION * FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS