



VOLUME TANK 2 = 10,768L

VOLUME TANK 1 = 29,856L

VOLUME TANK 3 = 10,768L

FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

▶▶ HOLD DOWN STRAP LOCATION

FITTING SCHEDULE		FIBRETANK SYSTEMS Pty Ltd	
25	100NB DUAL SOCKET	2 x 100NB BSP SOCKET	
23-24	600NB MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	
18-19	600NB MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	
9	100NB SOCKET	100NB BSP SOCKET	
8	100NB SOCKET	100NB BSP SOCKET	
6-7	100NB MONITOR	INTERSTICE MONITOR SOCKET	
2-3	600NB MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	
1	100NB DUAL SOCKET	2 x 100NB BSP SOCKET	
FLAT No.	SIZE	ITEM	DESCRIPTION
			Notes
			- Tie-Down Straps to suit this tank are STP part no.
			- Deduct to suit this tank are STP part no.
			- UNO, all sockets are BSP and are c/w striker plates under.
			Notes
			Revision Details
			By
			Date
DRAWN: M.P.	App. Weight: 3,700 kg	Construction	Type
DATE: 24-12-07	App. Capacity: 51,392 L	DOUBLE WALL	TYPE 50
		Compartment Configuration	TRIPLE 10/30/10
		DRAWING NUMBER:	FR 050000-000
		REVISION:	A

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF STP GROUP PTY LTD

FIBRETANK SYSTEMS Pty Limited
 PO BOX 102
 CARRINGTON, NSW 2294
 Ph:(02)4961-2745 Fax:(02)4962-2812