



TANK 1 VOLUME = 29,744 L

TANK 2 VOLUME = 25,032 L

FITTING SCHEDULE		FIBRETANK SYSTEMS Pty Limited	
27	100NB SOCKET	100NB BSP SOCKET	
26	100NB SOCKET	100NB BSP SOCKET	
25	100NB SOCKET	100NB BSP SOCKET	
23-24	100NB MONITOR	INTERSTICE MONITOR SOCKET	
17-22	100NB SOCKET	100NB BSP SOCKET	
13	100NB SOCKET	100NB BSP SOCKET	
6	100NB MONITOR	100NB BSP SOCKET	
4-5	100NB SOCKET	INTERSTICE MONITOR SOCKET	
2-3	100NB SOCKET	100NB BSP SOCKET	
1	100NB SOCKET	100NB BSP SOCKET	
FLAT No.	SIZE	ITEM	
DRAWN: V.B.B.		App. Weight: 2,752 kg	Construction Type
DATE: 25-07-01		App. Capacity: 54,776 L	
		DOUBLE WALL	TYPE 55
		Notes	
		- Tie-Down Straps to suit this tank are part no.	
		- Deadmen to suit this tank are part no.	
		- UNO, all sockets are BSP and are c/w striker plates under.	
		A Original Issue	
		Revision Details	
		No	By
		Revision Number: FK 055000-000	
		DRAWING NUMBER: FK 055000-000	
		REVISION: A	

▶▶ HOLD DOWN STRAP LOCATION

\* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited  
PO BOX 102  
CARRINGTON., NSW 2294  
Ph:(02)4961-2745 Fax:(02)4962-2812