



TANK 1 VOLUME = 35,240 L

TANK 2 VOLUME = 19,742 L

FITTING SCHEDULE		FIBRETANKS SYSTEMS Pty Limited	
25	100NB SOCKET	100NB BSP SOCKET	
24	100NB SOCKET	100NB BSP SOCKET	
20 - 21	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	
16	100NB SOCKET	100NB BSP SOCKET	
6-7	100NB MONITOR	INTERSTICE MINITOR SOCKET	
5	100NB SOCKET	100NB BSP SOCKET	
2-3	600NB MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	
FLAT No.	SIZE	ITEM	DESCRIPTION
DRAWN: V.B.B.	App. Weight:	3,800 kg	Construction Type
DATE: 2-07-02	App. Capacity:	54,982 L	DOUBLE WALL TYPE 55
		Notes	
		- Tie-Down Straps to suit this tank are part no.	
		- Deadmen to suit this tank are part no.	
		- UNO, all sockets are BSP and are c/w striker plates under.	
		A Original Issue	
		Revision Details	
		No	
		DRAWING NUMBER: FE 055000-009	
		REVISION: A	

FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

▶▶ HOLD DOWN STRAP LOCATION

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
PO BOX 102
CARRINGTON, NSW 2294
Ph:(02)4961-2745 Fax:(02)4962-2812