



TANK 2 VOLUME = 19,740 L

TANK 1 VOLUME = 20,882 L

TANK 3 VOLUME = 14,358 L

▶▶ HOLD DOWN STRAP LOCATION * FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		NOTES		REVISION:	
FLAT No.	SIZE	ITEM	DESCRIPTION	No	Revision Details	By	Date
26-27	100NB	SOCKET	100NB BSP SOCKET				
23-24	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID				
17-18	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID				
13-14	100NB	SOCKET	100NB BSP SOCKET				
7-8	100NB	MONITOR	INTERSTICE MONITOR SOCKET				
4-5	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID				
1-2	100NB	SOCKET	100NB BSP SOCKET	A	Original Issue		

DRAWN: M.A.P.		App. Weight: 3,800kg		Construction Type		DRAWING NUMBER:					
DATE: 16.10.07		App. Capacity: 54,980 L		DOUBLE WALL TYPE 55		FR 055000-002					
<p>The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.</p>				<p>All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.</p>				<p>THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED</p>			
<p>FIBRETANK SYSTEMS Pty Limited PO BOX 102 CARRINGTON, NSW 2294 Ph:(02)4961-2745 Fax:(02)4962-2812</p>				<p>REVISION: A</p>							