



TANK 1 VOLUME  
32,729 L APPROX

TANK 2 VOLUME  
29,457 L APPROX

▶▶ HOLD DOWN STRAP LOCATION \* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		Notes		Revision Details	
FLAT No.	SIZE	ITEM		No	Revision	By	Date
14	100NB	SOCKET	100NB BSP SOCKET				
13	100NB	SOCKET	100NB BSP SOCKET				
12	100NB	SOCKET	100NB BSP SOCKET				
11	100NB	SOCKET	100NB BSP SOCKET				
10	100NB	SOCKET	100NB BSP SOCKET				
8-9	100NB	MONITOR	INTERSTICE MONITOR SOCKET				
3-5	100NB	SOCKET	100NB BSP SOCKET				
2	100NB	SOCKET	100NB BSP SOCKET				
1	100NB	SOCKET	100NB BSP SOCKET				
	100NB	SOCKET	100NB BSP SOCKET				

DRAWN: V.B.B.		App. Weight: 2,680 KG		Construction Type		Compartment Configuration		DRAWING NUMBER:		REVISION:					
DATE: 25-07-01		App. Capacity: 62,186 L		DOUBLE WALL TYPE 60		DOUBLE 30/30		FK 060000-000		A					
<p>The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes &amp; fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested &amp; installed as per current specifications and instructions.</p>				<p>All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.</p>				<p>THIS DRAWING &amp; THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL &amp; MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED</p>				<p>FIBRETANK SYSTEMS Pty Limited PO BOX 102 CARRINGTON., NSW 2294 Ph:(02)4961-2745 Fax:(02)4962-2812</p>			