



TANK 1 VOLUME
32,729 L APPROX

TANK 2 VOLUME
29,457 L APPROX

▶ ▶ HOLD DOWN STRAP LOCATION

* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		FIBRETANK SYSTEMS Pty Limited	
DOMES	100NB	SOCKET	100NB BSP SOCKET
12-13	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID
10	100NB	SOCKET	100NB BSP SOCKET
8-9	100NB	MONITOR	INTERSTICE MONITOR SOCKET
5	100NB	SOCKET	100NB BSP SOCKET
2-3	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID
DOMES	100NB	SOCKET	100NB BSP SOCKET
FLAT NO.	SIZE	ITEM	DESCRIPTION

DRAWN: V.B.B. App. Weight: 2,768 kg

DATE: 31-07-01 App. Capacity: 62,186 L

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
PO BOX 102
CARRINGTON, NSW 2294
Ph:(02)4961-2745 Fax:(02)4962-2812

Construction	Type	Compartment Configuration	DRAWING NUMBER:	REVISION:
DOUBLE WALL	TYPE 60	DOUBLE	FE 060000-000	A