



◆◆ HOLD DOWN STRAP LOCATION \* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		NOTES		DRAWING NUMBER:		REVISION:	
FLAT No.	SIZE	ITEM	DESCRIPTION	Notes	No	Revision Details	By	Date	
14	100NB	SOCKET	100NB BSP SOCKET						
12-13	100NB	MONITOR	INTERSTICE MONITOR SOCKET						
8	100NB	SOCKET	100NB BSP SOCKET	- Tie-Down Straps to suit this tank are part no.					
4-5	100NB	MONITOR	INTERSTICE MONITOR SOCKET	- Dedmen to suit this tank are part no.					
2-3	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	- UNO, all sockets are BSP and are c/w striker plates under.	A	Original Issue			
DRAWN: V.B.B.		App. Weight: 2,710 kg		Construction Type		DRAWING NUMBER: FD 060000-000		REVISION: A	
DATE: 24-07-01		App. Capacity: 62,186 L		DOUBLE WALL TYPE 60		SINGLE			

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited  
 PO BOX 102  
 CARRINGTON., NSW 2294  
 Ph:(02)4961-2745 Fax:(02)4962-2812