



▶◀ HOLD DOWN STRAP LOCATION

* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE

FLAT No.	SIZE	ITEM	DESCRIPTION	Notes	No	Revision Details	By	Date
29-30	100NB	SOCKET	100NB BSP SOCKET					
26-27	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID					
21-22	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID					
17-18	100NB	SOCKET	100NB BSP SOCKET					
7-8	100NB	MONITOR	INTERSTICE MONITOR SOCKET	- Tie-Down Straps to suit this tank are part no.				
4-5	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	- Deadmen to suit this tank are part no.				
1-2	100NB	SOCKET	100NB BSP SOCKET	- UNO, all sockets are BSP and are c/w striker plates under.	A	Original Issue	-	-

DRAWN: MP	App. Weight: 5,500kg	Construction Type	DOUBLE WALL TYPE 60	Compartment Configuration	TRIPLE 20/25/15	DRAWING NUMBER:	FR 060000-001	REVISION:	A
DATE: 20.6.08	App. Capacity: 60,000 L								

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
PO BOX 102
CARRINGTON., NSW 2294
Ph:(02)4961-2745 Fax:(02)4962-2812