



TANK 1 VOLUME = 39,275 L

TANK 2 VOLUME = 32,730 L

▶▶ HOLD DOWN STRAP LOCATION

* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		FIBRETANK SYSTEMS Pty Limited	
17	100NB SOCKET	100NB BSP SOCKET	
16	100NB SOCKET	100NB BSP SOCKET	
15	100NB SOCKET	100NB BSP SOCKET	
13	100NB SOCKET	100NB BSP SOCKET	
12	100NB SOCKET	100NB BSP SOCKET	
10-11	100NB MONITOR	INTERSTIE MONITOR SOCKET	
5 - 7	100NB SOCKET	100NB BSP SOCKET	- Tie-Down Straps to suit this tank are part no.
3	100NB SOCKET	100NB BSP SOCKET	- Dedmen to suit this tank are part no.
2	100NB SOCKET	100NB BSP SOCKET	- UNQ, all sockets are BSP and are c/w striker plates under.
1	100NB SOCKET	100NB BSP SOCKET	
FLAT No.	SIZE	ITEM	Notes
			Revision Details
			By
			Date

DRAWN: V.B.B. App. Weight: 3,090 kg

DATE: 25-07-01 App. Capacity: 72,005 L

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
PO BOX 102
CARRINGTON, NSW 2294
Ph:(02)4961-2745 Fax:(02)4962-2812

DOUBLE WALL TYPE 70 DOUBLE 40/30 DRAWING NUMBER: FK 070000-000 REVISION: A