



▲▲ HOLD DOWN STRAP LOCATION \* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		NOTES		DRAWING NUMBER:		REVISION:	
FLAT No.	SIZE	ITEM	DESCRIPTION	Notes	No	Revision Details	By	Date	
17	100NB	SOCKET	100NB BSP SOCKET						
15-16	100NB	MONITOR	INTERSTICE MONITOR SOCKET						
10	100NB	SOCKET	100NB BSP SOCKET	- Tie-Down Straps to suit this tank are part no.					
4-5	100NB	MONITOR	INTERSTICE MONITOR SOCKET	- Deadmen to suit this tank are part no.					
2-3	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	- UNQ, all sockets are BSP and are c/w striker plates under.	A	Original Issue			
					No	Revision Details			

DRAWN: V.B.B. App. Weight: 3,260 KG

DATE: 24-07-01 App. Capacity: 75,278 L

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The Tanks shall be "Century-Cast" Tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

Construction Type: DOUBLE WALL TYPE 75

Compartment Configuration: SINGLE

DRAWING NUMBER: FD 075000-000

REVISION: A

All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited  
 PO BOX 102  
 CARRINGTON, NSW 2294  
 Ph:(02)4961-2745 Fax:(02)4962-2812

US EMBASSY BEIJING