



TANK 2 VOLUME = 26,137 L APPROX TANK 1 VOLUME = 23,748 L APPROX TANK 3 VOLUME = 22,870 L APPROX

▶▶ HOLD DOWN STRAP LOCATION * FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		FIBRETANK SYSTEM STD	
DOME	100NB	SOCKET	100NB BSP SOCKET
16	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID
18	100NB	SOCKET	2x100NB BSP SOCKETS
13-14	100NB	MONITOR	INTERSTICE MONITOR SOCKET
10-11	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID
8	100NB	SOCKET	100NB BSP SOCKET
4 & 9	100NB	SOCKET	2x100NB BSP SOCKETS
4-5	100NB	MONITOR	INTERSTICE MONITOR SOCKET
2	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID
DOME	100NB	SOCKET	100NB BSP SOCKET
FLAT No.	SIZE	ITEM	DESCRIPTION

DRAWN: KJM	App. Weight: 3,246 kg	Construction	Type	Compartment Configuration	DRAWING NUMBER:	REVISION:
DATE: July.07	App. Capacity: 72,755 L	DOUBLE WALL	TYPE 75	TRIPLE 25/25/25	FR-DW-TC-P 075000-001	A

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
 PO BOX 102
 CARRINGTON., NSW 2294
 Ph:(02)4961-2745 Fax:(02)4962-2812