



TANK 2 VOLUME = 29,400 L APPROX

TANK 1 VOLUME = 50,000 L APPROX

▶ ◀ HOLD DOWN STRAP LOCATION

\* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE	FLAT No.	SIZE	ITEM	DESCRIPTION	Notes	Revision Details		By	Date
						No	Revision Details		
					FIBRETANK SYSTEMS Pty Ltd				
	19	100NB	SOCKET	100NB BSP SOCKET					
	17-18	100NB	MONITOR	INTERSTICE MONITOR SOCKET					
	16	100NB	SOCKET	100NB BSP SOCKET					
	11-12	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID					
	4-5	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	- Tie-Down Straps to suit this tank are part no.				
	2	100NB	SOCKET	100NB BSP SOCKET	- Deadmen to suit this tank are part no.				
	1	100NB	DUPLEX	2 x 100NB BSP SOCKET	- UNO, all sockets are BSP and are c/w striker plates under.	A	Original Issue	-	-

DRAWN: M.P.	App. Weight: 4,900 kg	Construction Type	DOUBLE WALL TYPE 80	Compartment Configuration	DOUBLE 30/50	DRAWING NUMBER:	FE 080000-003	REVISION:	A
DATE: 4-08-08	App. Capacity: 79,400 L								

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited  
PO BOX 102  
CARRINGTON., NSW 2294  
Ph:(02)4961-2745 Fax:(02)4962-2812