



TANK 1 VOLUME = 52,367 L

TANK 2 VOLUME = 39,276 L

▶◀ HOLD DOWN STRAP LOCATION

\* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE

FLAT No.	SIZE	ITEM	DESCRIPTION	Notes	No	Revision Details	By	Date
				FIBRETANK SYSTEMS Pty Limited				
23	100NB	SOCKET	100NB BSP SOCKET					
21 - 22	100NB	MONITOR	INTERSTICE MONITOR SOCKET					
20	100NB	SOCKET	100NB BSP SOCKET					
17 - 18	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID					
11	100NB	SOCKET	100NB BSP SOCKET					
7-8	100NB	MONITOR	INTERSTICE MONITOR SOCKET	- Tie-Down Straps to suit this tank are part no.				
6	100NB	SOCKET	100NB BSP SOCKET	- Deadmen to suit this tank are part no.				
2 - 3	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	- UNO, all sockets are BSP and are c/w striker plates under.	A	Original Issue	-	-

DRAWN: V.B.B.	App. Weight: 3,785 kg	Construction	Type	Compartment Configuration	DRAWING NUMBER:	REVISION:
DATE: 1-08-01	App. Capacity: 91,643 L	DOUBLE WALL	TYPE 90	DOUBLE 50/40	FE 090000-000	A

<p>The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes &amp; fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested &amp; installed as per current specifications and instructions.</p>	<p>All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.</p>	<p>THIS DRAWING &amp; THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL &amp; MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED</p>	<p>FIBRETANK SYSTEMS Pty Limited PO BOX 102 CARRINGTON., NSW 2294 Ph:(02)4961-2745 Fax:(02)4962-2812</p>
---	---	---	--