



FIBRETANK SYSTEMS Pty Limited  
 \* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		Notes		Revision Details	
FLAT No.	SIZE	ITEM	DESCRIPTION	No	Original Issue	By	Date
23	100NB	SOCKET	100NB BSP SOCKET				
21-22	100NB	MONITOR	INTERSTICE MONITOR SOCKET				
13	100NB	SOCKET	100NB BSP SOCKET				
5-6	100NB	MONITOR	INTERSTICE MONITOR SOCKET				
2-3	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB BSP SOCKETS, RISER & LID	A	Original Issue		

DRAWN: V.B.B.		App. Weight: 4,070 kg		Construction Type		DOUBLE WALL TYPE 90		Compartment Configuration		DRAWING NUMBER: FD 090000-000		REVISION: A	
DATE: 24-07-01		App. Capacity: 91,643 L		Description		DOUBLE WALL TYPE 90		SINGLE		FD 090000-000		A	

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited  
 PO BOX 102  
 CARRINGTON., NSW 2294  
 Ph:(02)4961-2745 Fax:(02)4962-2812