



VOLUME TANK 1 = 26,184 LITRES

VOLUME TANK 2 = 39,275 LITRES

VOLUME TANK 3 = 26,184 LITRES

SMITHFIELD PROJECT
For TFA PROJECTS

▶▶ HOLD DOWN STRAP LOCATION

* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		Notes		Revision Details	
DOME	SIZE	ITEM		No	Original Issue	By	Date
23	100NB	SOCKET	100NB BSP SOCKET				
22 - 23	100NB	SOCKET	100NB BSP SOCKET				
20 - 21	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB BSP SOCKETS, RISER & LID				
13 - 14	100NB	SOCKET	100NB BSP SOCKET				
10-11	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB BSP SOCKETS, RISER & LID				
6-7	100NB	MONITOR	INTERSTICE MONITOR SOCKET				
3-4	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB BSP SOCKETS, RISER & LID				
1	100NB	SOCKET	100NB BSP SOCKET				
DOME	100NB	SOCKET	100NB BSP SOCKET	A	Original Issue		
FLAT No.	SIZE	ITEM		No			

DRAWN: V.B.B.	App. Weight: 4,570 kg	Construction	Type	Compartment Configuration	DRAWING NUMBER:	REVISION:
DATE: 23-10-03	App. Capacity: 91,643 L	DOUBLE WALL	TYPE 90	TRIPLE 25/40/25	FR 090000-001	A

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
PO BOX 102
CARRINGTON, NSW 2294
Ph:(02)4961-2745 Fax:(02)4962-2812