



TANK 1 VOLUME = 62,186 L

TANK 2 VOLUME = 49,095 L

| FITTING SCHEDULE | | DESCRIPTION | | Notes | | Revision Details | |
|------------------|-------|-------------|--|-------|----------------|------------------|------|
| FLAT No. | SIZE | ITEM | DESCRIPTION | No | Original Issue | By | Date |
| 27-28 | 600NB | MANHOLE | MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID | | | | |
| 24 | 100NB | SOCKET | 100NB BSP SOCKET | | | | |
| 20 | 100NB | SOCKET | 100NB BSP SOCKET | | | | |
| 13 | 100NB | SOCKET | 100NB BSP SOCKET | | | | |
| 6 | 100NB | SOCKET | 100NB BSP SOCKET | | | | |
| 2-3 | 600NB | MANHOLE | MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID | A | Original Issue | | |

| | | | | | |
|---------------------------------|---|--|--|---|-----------------------|
| DRAWN: V.B.B. DATE: 01-08-01 | App. Weight: 3,655 kg App. Capacity: 111,281 L | Construction Type SINGLE WALL TYPE 110 | Notes - Tie-Down Straps to suit this tank are part no. - Dedmen to suit this tank are part no. - UNO, all sockets are BSP and are c/w striker plates under. | Drawing Number: FT 110000-000 | Revision: A |
|---------------------------------|---|--|--|---|-----------------------|

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The Tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
 PO BOX 102
 CARRINGTON, NSW 2294
 Ph:(02)4961-2745 Fax:(02)4962-2812

◆◆ HOLD DOWN STRAP LOCATION * FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS