



TANK 1 VOLUME = 39,276 LITRES APPROX

TANK 2 VOLUME = 72,005 LITRES APPROX

RUTHVEN STREET  
SERVICE STATION

for TANK SOLUTIONS

▶▶ HOLD DOWN STRAP LOCATION

\* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		Notes		Revision Details	
FLAT No.	SIZE	ITEM		No	By	Date	
29	100NB	SOCKET	100NB BSP SOCKET				
24	100NB	SOCKET	100NB BSP SOCKET				
23	100NB	SOCKET	100NB BSP SOCKET				
18-19	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID				
8-9	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID				
5	100NB	SOCKET	100NB BSP SOCKET	C	MANWAY UPDATED	V.B.B. 20-3-02	
2	100NB	SOCKET	100NB BSP SOCKET	B	UPDATED AS PER CADWAY DWG No. 10234-101	V.B.B. 26-2-02	
1	100NB	SOCKET	100NB BSP SOCKET	A	Original Issue	V.B.B. 26-2-02	

DRAWN: V.B.B.	App. Weight: 3,510 kg	Construction Type	DOUBLE 40/70	DRAWING NUMBER: FG 110000-001	REVISION: C
DATE: 17-09-01	App. Capacity: 111,281 L	SINGLE WALL TYPE 110	DOUBLE		

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The Tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited  
PO BOX 102  
CARRINGTON., NSW 2294  
Ph:(02)4961-2745 Fax:(02)4962-2812