



TANK 1 - 26,182 LITRES APPROX

TANK 1 - 49,094 LITRES APPROX

TANK 1 - 36,005 LITRES APPROX

▶▶ HOLD DOWN STRAP LOCATION

\* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		FIBRETANK SYSTEMS Pty Limited	
27-28	600NB MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	
25	100NB SOCKET	100NB BSP SOCKET	
23 - 24	100NB SOCKET	100NB BSP SOCKET	
17-18	600NB MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	
13 - 15	100NB SOCKET	100NB BSP SOCKET	
9	100NB SOCKET	100NB BSP SOCKET	
1-2	600NB MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	
1	100NB DUPLEX	2 x 100NB BSP SOCKET	
DOME	100NB SOCKET	100NB BSP SOCKET	
FLAT No.	SIZE	ITEM	

DRAWN: V.B.B. App. Weight: 3,320 kg

DATE: 13-11-02 App. Capacity: 111,281 L

Construction

SINGLE WALL

Type

TYPE 110

Compartment Configuration

TRIPLE

DRAWING NUMBER:

FL 110000-005

REVISION:

A

Notes

- Tie-Down Straps to suit this tank are part no.

- Deckmen to suit this tank are part no.

- UNO, all sockets are BSP and are c/w striker plates under.

No

A Original Issue

B DUPLEX ON DOME WAS SINGLE/EXTRA SOCKETS 15-24

C SINGLE SOCKET ON DOME WAS DUPLEX

Revision Details

By

Date

V.B.B. 5-07-02

V.B.B. 8-2-02

- -

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited  
PO BOX 102  
CARRINGTON., NSW 2294  
Ph:(02)4961-2745 Fax:(02)4962-2812