



◆◆ HOLD DOWN STRAP LOCATION * FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		Notes		Revision Details	
FLAT No.	SIZE	ITEM		No	Revision	By	Date
DOME 2	100NB	SOCKET	100NB BSP SOCKET				
5	100NB	SOCKET	100NB BSP SOCKET				
4	100NB	SOCKET	100NB BSP SOCKET				
2	100NB	SOCKET	100NB BSP SOCKET				
1	100NB	SOCKET	100NB BSP SOCKET	A	Original Issue		

DRAWN: V.B.B.		App. Weight: 2,674 KG		Construction		Type		Compartment Configuration		DRAWING NUMBER:		REVISION:	
DATE: 08-06-01		App. Capacity: 51,200 L		SINGLE WALL		TYPE 15		SINGLE		FE 050000-000		A	

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
 PO BOX 102
 CARRINGTON., NSW 2294
 Ph:(02)4961-2745 Fax:(02)4962-2812