



◆◆ HOLD DOWN STRAP LOCATION

* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		NOTES		REVISION					
DOMES	100NB	SOCKET	100NB BSP SOCKET	- Tie-Down Straps to suit this tank are part no.							
5	100NB	SOCKET	100NB BSP SOCKET	- Deadmen to suit this tank are part no.							
2-3	600NB	MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	- UNO, all sockets are BSP and are c/w striker plates under.							
FLAT No.	SIZE	ITEM									
DRAWN: V.B.B.		App. Weight:	561 KG	Construction		Type	Compartment Configuration	DRAWING NUMBER:	FP 015000-000	REVISION:	A
DATE: 19-07-01		App. Capacity:	15,440 L	Construction		TYPE 15	SINGLE				

FIBRETANK SYSTEMS PTY LIMITED

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
 PO BOX 102
 CARRINGTON, NSW 2294
 Ph:(02)4961-2745 Fax:(02)4962-2812