



* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		NOTES		REVISIONS	
8	100NB SOCKET	100NB BSP SOCKET	- Tie-Down Straps to suit this tank are STP part no.	No	Original Issue		
7	100NB SOCKET	100NB BSP SOCKET	- Deducted to suit this tank are STP part no.	A			
2-3	600NB MANHOLE	MANHOLE c/w COVER & 5 x 100NB SOCKETS, RISER & LID	- UNO, all sockets are BSP and are c/w striker plates under.				
	FLAT No.	ITEM	DESCRIPTION		Revision Details	By	Date

DRAWN: V.B.B.	App. Weight: 718 kg	Construction	Type	Compartment Configuration	DRAWING NUMBER:	REVISION:
DATE: 13-07-01	App. Capacity: 20,804 L	SINGLE WALL	TYPE 20	SINGLE	FP 020000-000	A

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF STP GROUP PTY LTD

FIBRETANK SYSTEMS Pty Limited
 PO BOX 102
 CARRINGTON., NSW 2294
 Ph:(02)4961-2745 Fax:(02)4962-2812