



TANK 1 VOLUME  
15,440 L APPROX

TANK 2 VOLUME  
10,728 L APPROX

▶▶ HOLD DOWN STRAP LOCATION \* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

FITTING SCHEDULE		DESCRIPTION		Notes		Revision Details	
FLAT No.	SIZE	ITEM		No	Original Issue	By	Date
			FIBRETANK SYSTEMS Pty Limited				
DOME	100NB	SOCKET	100NB BSP SOCKET				
11	100NB	SOCKET	100NB BSP SOCKET				
10	100NB	DUPLEX	2 x 100NB BSP SOCKET				
9	100NB	SOCKET	100NB BSP SOCKET				
4	100NB	SOCKET	100NB BSP SOCKET				
2	100NB	DUPLEX	2 x 100NB BSP SOCKET		- Tie-Down Straps to suit this tank are part no.		
1	100NB	SOCKET	100NB BSP SOCKET		- Dedmen to suit this tank are part no.		
DOME	100NB	SOCKET	100NB BSP SOCKET		- UNQ, all sockets are BSP and are c/w striker plates under.		

DRAWN: V.B.B.	App. Weight: 1,020 kg	Construction Type	DOUBLE	DRAWING NUMBER:	FG 025000-000	REVISION:	A
DATE: 31-07-01	App. Capacity: 26,168 L	SINGLE WALL	TYPE 25	Compartment Configuration	DOUBLE 15/10		

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited  
PO BOX 102  
CARRINGTON., NSW 2294  
Ph:(02)4961-2745 Fax:(02)4962-2812