



FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

▶ ▶ HOLD DOWN STRAP LOCATION

FITTING SCHEDULE		DESCRIPTION		Notes		Revision Details	
FLAT No.	SIZE	ITEM		No	Original Issue	By	Date
11	100NB	SOCKET	100NB BSP SOCKET				
10	100NB	SOCKET	100NB BSP SOCKET				
9	100NB	SOCKET	100NB BSP SOCKET				
7	100NB	SOCKET	100NB BSP SOCKET				
2	100NB	SOCKET	100NB BSP SOCKET	A	Original Issue		

FIBRETANK SYSTEMS Pty Limited

DRAWN: V.B.B. App. Weight: 880 kg

DATE: 25-07-01 App. Capacity: 26,168 L

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited
PO BOX 102
CARRINGTON., NSW 2294
Ph:(02)4961-2745 Fax:(02)4962-2812

Construction Type SINGLE WALL TYPE 25

Compartment Configuration SINGLE

DRAWING NUMBER: FS 025000-000

REVISION: A