



TANK 1 VOLUME = 8,950 L      TANK 2 VOLUME = 11,916 L      TANK 3 VOLUME = 8,950 L

| FITTING SCHEDULE |              | FIBRETANK SYSTEMS Pty Limited |               |
|------------------|--------------|-------------------------------|---------------|
| DOMES            | 100NB SOCKET | 100NB SOCKET                  |               |
| 13               | 100NB SOCKET | 100NB SOCKET                  |               |
| 12               | 100NB SOCKET | 2 x 100NB SOCKETS (DUPEX)     |               |
| 11               | 100NB SOCKET | 100NB SOCKET (VENT ONLY)      |               |
| 8                | 100NB SOCKET | 2 x 100NB SOCKETS (DUPEX)     |               |
| 6                | 100NB SOCKET | 2 x 100NB SOCKETS (DUPEX)     |               |
| 3                | 100NB SOCKET | 100NB SOCKET (VENT ONLY)      |               |
| 2                | 100NB SOCKET | 2 x 100NB SOCKETS (DUPEX)     |               |
| 1                | 100NB SOCKET | 100NB SOCKET                  |               |
| DOMES            | 100NB SOCKET | 100NB SOCKET                  |               |
| FLAT No.         | SIZE         | ITEM                          | DESCRIPTION   |
| DRAWN: V.B.B.    |              | App. Weight:                  | 1,400 KG      |
| DATE: 08-06-01   |              | App. Capacity:                | 30,200 L      |
| Construction     |              | Type                          | TYPE 30       |
| SINGLE WALL      |              | Compartment Configuration     | TRIPLE        |
| Notes            |              | DRAWING NUMBER:               | FH 030000-000 |
| Revision Details |              | No                            | By            |
| Original Issue   |              | A                             |               |
| Date             |              |                               |               |

▶▶ HOLD DOWN STRAP LOCATION \* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS

The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage tanks as illustrated. Sizes & fittings shall be as noted. The tanks shall be "Century-Cast" tanks as manufactured by Fibretank Systems. Tanks shall be tested & installed as per current specifications and instructions.

All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.

THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED

FIBRETANK SYSTEMS Pty Limited  
PO BOX 102  
CARRINGTON., NSW 2294  
Ph:(02)4961-2745 Fax:(02)4962-2812