



FITTING SCHEDULE		DESCRIPTION		Notes		Revision Details	
FLAT No.	SIZE	ITEM			No	Original Issue	By
13	100NB	SOCKET	100NB BSP SOCKET				
12	100NB	SOCKET	100NB BSP SOCKET				
11	100NB	SOCKET	100NB BSP SOCKET	- Tie-Down Straps to suit this tank are part no.			
8	100NB	SOCKET	100NB BSP SOCKET	- Dedmen to suit this tank are part no.			
2	100NB	SOCKET	100NB BSP SOCKET	- UNO, all sockets are BSP and are c/w striker plates under.	A		

DRAWN: V.B.B.		App. Weight: 931 kg		Construction		Type		Compartment Configuration		DRAWING NUMBER:		REVISION:			
DATE: 25-07-01		App. Capacity: 29,744 L		SINGLE WALL		TYPE 30		SINGLE		FS 030000-000		A			
<p>The contractor shall provide Fibreglass Reinforced Plastic (FRP) underground storage Tanks as illustrated. Sizes & fittings shall be as noted. The Tanks shall be "Century-Cast" Tanks as manufactured by Fibretank Systems Tanks shall be tested & installed as per current specifications and instructions.</p>				<p>All dimensions in millimetres. All dimensions are nominal unless a manufacturing tolerance has been specified.</p>				<p>THIS DRAWING & THE INFORMATION CONTAINED HEREIN IS THE PROPERTY OF FIBRE TANK SYSTEMS AND STRICTLY CONFIDENTIAL & MUST NOT BE USED OR DISCLOSED WITHOUT WRITTEN CONSENT OF FIBRETANK SYSTEMS PTY LIMITED</p>				<p>FIBRETANK SYSTEMS Pty Limited PO BOX 102 CARRINGTON., NSW 2294 Ph:(02)4961-2745 Fax:(02)4962-2812</p>			

FIBRETANK SYSTEMS Pty Limited

▶▶ HOLD DOWN STRAP LOCATION

* FITTINGS CANNOT BE INSTALLED IN THESE LOCATIONS